



2012002878Z



检测
CNAS L1020



(2012)国认监认字(347)号

国家强制性产品认证 试验报告

■新申请 □变更 □监督 □复审 □其他:

申请编号: A2012CCC0304-1320802

(任务编号)

产品名称: 交流接触器

型 号: NC100-0910, NC100-0901, NC100-0910N, NC100-0901N
NC100-1210, NC100-1201, NC100-1210N, NC100-1201N
NC100-1810, NC100-1801, NC100-1810N, NC100-1801N
NC100-2210, NC100-2201, NC100-2210N, NC100-2201N

检测机构: 苏州电器科学研究院股份有限公司



样品名称: 交流接触器 型号: NC100-0910, NC100-0901 NC100-0910N, NC100-0901N NC100-1210, NC100-1201, NC100-1210N, NC100-1201N NC100-1810, NC100-1801, NC100-1810N, NC100-1801N NC100-2210, NC100-2201, NC100-2210N, NC100-2201N	委托人: 浙江正泰电器股份有限公司 委托人地址: 浙江省乐清市北白象镇正泰工业园区正泰路1号 生产者(制造商): 浙江正泰电器股份有限公司 生产者(制造商)地址: 浙江省乐清市北白象镇正泰工业园区正泰路1号 生产企业: 浙江正泰电器股份有限公司 生产企业地址: 浙江省乐清市北白象镇正泰工业园区正泰路1号
数量: 34 台	
收样日期: 2012-06-19	
完成日期: 2012-07-06	
样品来源: 工厂送样	
试验结论: 合格	
本申请认证单元所覆盖的产品型号规格及相关情况说明: NC100-0910, NC100-0901, NC100-0910N, NC100-0901N, NC100-1210, NC100-1201, NC100-1210N, NC100-1201N, NC100-1810, NC100-1801, NC100-1810N, NC100-1801N, NC100-2210, NC100-2201, NC100-2210N, NC100-2201N Ui: 690V Ith: NC100-0910, NC100-0901, NC100-0910N, NC100-0901N, NC100-1210, NC100-1201, NC100-1210N, NC100-1201N: 20A; NC100-1810, NC100-1801, NC100-1810N, NC100-1801N, NC100-2210, NC100-2201, NC100-2210N, NC100-2201N: 32A; NC100-0910, NC100-0901: AC-3: AC230(220)V/ AC400(380)V/9A, AC690(660)V/6.6A; AC-4: AC230(220)V/ AC400(380)V/3.5A, AC690(660)V/1.5A; NC100-0910N, NC100-0901N: AC-4: AC230(220)V/ AC400(380)V/3.5A, AC690(660)V/1.5A; NC100-1210, NC100-1201: AC-3: AC230(220)V/ AC400(380)V/12A, AC690(660)V/8.9A; AC-4: AC230(220)V/ AC400(380)V/5A, AC690(660)V/2A; NC100-1210N, NC100-1201N: AC-4: AC230(220)V/ AC400(380)V/5A, AC690(660)V/2A; NC100-1810, NC100-1801: AC-3: AC230(220)V/ AC400(380)V/18A, AC690(660)V/12A; AC-4: AC230(220)V/ AC400(380)V/7.7A, AC690(660)V/3.8A; NC100-1810N, NC100-1801N: AC-4: AC230(220)V/ AC400(380)V/7.7A, AC690(660)V/3.8A; NC100-2210, NC100-2201: AC-3: AC230(220)V/ AC400(380)V/22A, AC690(660)V/14A; AC-4: AC230(220)V/ AC400(380)V/7.7A, AC690(660)V/3.8A; NC100-2210N, NC100-2201N: AC-4: AC230(220)V/ AC400(380)V/7.7A, AC690(660)V/3.8A; Us: AC: 24V, 36V, 48V, 110V, 127V, 220V, 380V, 415V, 480V, 660V; 50Hz 极数: 3 极; IP10 辅助触头: Ith: 10A AC-15: Ue/Ie: 400(380)V/0.95A; DC-13: Ue/Ie: 250(220)V/0.15A;	
签发人: 胡德霖	
签名: 胡德霖	
签发日期: 2012-07-21	
备注: NC100-09**: #12#25#27 Us: 660V #01 Us: 480V #02 Us: 415V #03 Us: 380V #04 Us: 220V #05 Us: 127V #06 Us: 110V #07 Us: 48V #08 Us: 36V #09 Us: 24V #10 NC100-12**: #13#20#23 NC100-18**: #11#14#22#26 NC100-22**: #15#21#24 NC100-09**N: #16#31 NC100-12**N: #17 NC100-18**N: #18 NC100-22**N: #19 带镜像触头: (A)#28, (B)#29, (C)#30 (**=触头种类和数量, 用数字 10, 01 表示)	

安全型式试验报告

申请编号: A2012CCC0304-1320802
(任务编号)
样品名称: 交流接触器
型号规格: NC100-0910, NC100-0901,
NC100-0910N, NC100-0901N, NC100-1210,
NC100-1201, NC100-1210N, NC100-1201N,
NC100-1810, NC100-1801, NC100-1810N,
NC100-1801N, NC100-2210, NC100-2201,
NC100-2210N, NC100-2201N
样品数量: 34 台
样品生产序号: /
收样日期: 2012-06-19
样品来源: 工厂送样
抽样通知书编号: /

委托人: 浙江正泰电器股份有限公司
委托人地址: 浙江省乐清市北白象镇正泰工业园区正泰路1号
生产者(制造商): 浙江正泰电器股份有限公司
生产者(制造商)地址: 浙江省乐清市北白象镇正泰工业园区正泰路1号
生产企业: 浙江正泰电器股份有限公司
生产企业地址: 浙江省乐清市北白象镇正泰工业园区正泰路1号

试验依据标准: GB14048.4-2010《低压开关设备和控制设备 第4-1部分: 接触器和电动机起动器 机电式接触器和电动机起动器(含电动机保护器)》

试验结论: 合格

本申请认证单元所覆盖的产品型号规格及相关情况说明:

NC100-0910, NC100-0901, NC100-0910N, NC100-0901N, NC100-1210, NC100-1201, NC100-1210N, NC100-1201N,
NC100-1810, NC100-1801, NC100-1810N, NC100-1801N, NC100-2210, NC100-2201, NC100-2210N, NC100-2201N-32A;
Ui: 690V
Ith: NC100-0910, NC100-0901, NC100-0910N, NC100-0901N, NC100-1210, NC100-1201, NC100-1210N, NC100-1201N-20A;
NC100-1810, NC100-1801, NC100-1810N, NC100-1801N, NC100-2210, NC100-2201, NC100-2210N, NC100-2201N-32A;
NC100-0910, NC100-0901: AC-3: AC230(220)V/ AC400(380)V/9A, AC690(660)V/6.6A;
AC-4: AC230(220)V/ AC400(380)V/3.5A, AC690(660)V/1.5A;
NC100-0910N, NC100-0901N: AC-4: AC230(220)V/ AC400(380)V/3.5A, AC690(660)V/1.5A;
NC100-1210, NC100-1201: AC-3: AC230(220)V/ AC400(380)V/12A, AC690(660)V/8.9A;
AC-4: AC230(220)V/ AC400(380)V/5A, AC690(660)V/2A;
NC100-1210N, NC100-1201N: AC-4: AC230(220)V/ AC400(380)V/5A, AC690(660)V/2A;
NC100-1810, NC100-1801: AC-3: AC230(220)V/ AC400(380)V/18A, AC690(660)V/12A;
AC-4: AC230(220)V/ AC400(380)V/7.7A, AC690(660)V/3.8A;
NC100-1810N, NC100-1801N: AC-4: AC230(220)V/ AC400(380)V/7.7A, AC690(660)V/3.8A;
NC100-2210, NC100-2201: AC-3: AC230(220)V/ AC400(380)V/22A, AC690(660)V/14A;
AC-4: AC230(220)V/ AC400(380)V/7.7A, AC690(660)V/3.8A;
NC100-2210N, NC100-2201N: AC-4: AC230(220)V/ AC400(380)V/7.7A, AC690(660)V/3.8A;
Us: AC: 24V, 36V, 48V, 110V, 127V, 220V, 380V, 415V, 480V, 660V; 50Hz
极数: 3 极; IP10
辅助触头: Ith: 10A AC-15: Ue/Ie: 400(380)V/0.95A;
DC-13: Ue/Ie: 250(220)V/0.15A;

主检: 王文科 签名: 王文科 日期: 2012-07-31
审核: 王炜 签名: 王炜 日期: 2012-07-31
签发: 胡德霖 签名: 胡德霖 日期: 2012-07-31



备注

NC100-09**: #12#25#27 Us: 660V #01 Us: 480V #02 Us: 415V #03 Us: 380V #04 Us: 220V #05
Us: 127V #06 Us: 110V #07 Us: 48V #08 Us: 36V #09 Us: 24V #10
NC100-12**: #13#20#23 NC100-18**: #11#14#22#26 NC100-22**: #15#21#24
NC100-09**N: #16#31 NC100-12**N: #17 NC100-18**N: #18 NC100-22**N: #19
带镜像触头:(A)#28,(B)#29,(C)#30 (**=触头种类和数量,用数字10,01表示)