



## CB TEST CERTIFICATE

Ref. Certificate No.

NL-25640

### IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	CBI class Y		
Applicant:	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
Manufacturer:	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
Factory:	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
Rating and principal characteristics:	Ue: 415 / 690 Vac, Ui: 800 Vac, Uimp: 8 kV, In: 630 A, 700 A, 800 A 3P for the CBIs with reference /3000 3P+N(N pole is same to phase pole) for the CBIs with reference /4000 Icc = 10 In See annex for further ratings		
Trade mark (if any):	CHINT		
Model/Type reference:	NM1-800H/3000, NM1-800H/4000		
Additional information:	This certificate is also based on the certificate NL-18991 issued on 2010-09-20.		
Sample of product tested to be in conformity with IEC:	60947-2(ed.4);am1		
Test Report Ref. No:	W0808102.64 and 3304686.50		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.  
Utrechtseweg 310  
P.O. Box 5185  
6802 ED Arnhem  
The Netherlands

Signed by: F.S.Strikwerda

Date of issue: 2013-02-16

