



Ref. Certif. No.

SE-86996

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR
ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breakers for overcurrent protection

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
Zhejiang Province, P.R. CHINA

Name and address of the manufacturer

Same as above

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

See page 2

Trademark (if any)

CHNT

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

CB-60

Additional information (if necessary may also be
reported on page 2)

-

A sample of the product was tested and found
to be in conformity with

IEC 60898-1:2002+A1+A2

As shown in the Test Report Ref. No. which forms part
of this Certificate

170401232SHA-001, 170401232SHA-002, 170401232SHA-003,
170401232SHA-004

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 16 May 2017

Intertek

Signature:

Paul Klemets

Ratings and principal characteristics

$U_e = 240/415V\sim(1P), 415V\sim(2P, 3P, 4P)$

$I_n = 1, 2, 3, 4, 5, 6, 10, 16, 20, 25, 32, 40, 50, 60, 63A$ (for B-&C-type)

$I_n = 1, 2, 3, 4, 5, 6, 10, 16, 20, 25, 32, 40, 50, 60, 63A$ (for 1P&2P, D-type)

$I_n = 6, 10, 16, 20, 25, 32, 40, 50, 60, 63A$ (for 3P&4P, D-type)

B-, C- and D-type

$I_{cn} = I_{cs} = 6000A$ ($I_n = 1\sim 40A$, B-&C-type)

$I_{cn} = I_{cs} = 4500A$ ($I_n = 50\sim 63A$, B-&C-type, $I_n = 1\sim 63A$, D-type)

Additional information (if necessary)

Date: 16 May 2017

Signature: 