



Ref. Certif. No.

SE-87555

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR
ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded case circuit-breakers

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixiang,
Yueqing, Zhejiang Province, 325603, P.R. CHINA

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

Ue= 230V~(1P), 400V~(2, 3, 4P), 50Hz
In= 63, 80, 100, 125A
Cat. A, Ui= 500V
Icu= 10000A, Ics= 7500A

Trademark (if any)

CHNT

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

CB-125

Additional information (if necessary may also be
reported on page 2)

-

A sample of the product was tested and found
to be in conformity with

IEC 60947-2:2016

As shown in the Test Report Ref. No. which forms part
of this Certificate

170100610SHA-001, 170100610SHA-002,
170100610SHA-003, 170100610SHA-004

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Intertek

Signature:

Leif Söderlund

Leif Söderlund

Date: 5 July 2017