

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR
ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE


Product	Moulded case circuit-breakers
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, 325603, P.R. CHINA
Name and address of the manufacturer	Same as applicant
Name and address of the factory Note: When more than one factory, please report on page 2	Same as applicant
Ratings and principal characteristics	Ue= 240V~(1P), 415V~(2, 3, 4P), 50/60Hz, In= 63, 80, 100, 125A; Cat. A, Ui= 500V, DZ158-125H: Icu= 10000A, Ics= 7500A, DZ158-125: Icu= Ics= 6000A
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	DZ158-125H, DZ158-125
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	170100608SHA-001, 170100608SHA-002, 170100608SHA-003, 170100608SHA-004

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 4 July 2017



Signature: 

Leif Söderlund