



## CB TEST CERTIFICATE

Ref. Certificate No.

NL-18075

### IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by: KEMA Quality B.V.  
Product: Current transformers

Applicant:	Zhejiang Chint Electronics Co. Ltd.	CHINT High-Tech Industrial Zone, North Baixiang, Yueqing 325603 Wenzhou Zhejiang	China
Manufacturer:	Zhejiang Chint Electronics Co. Ltd.	CHINT High-Tech Industrial Zone, North Baixiang, Yueqing 325603 Wenzhou Zhejiang	China
Factory:	Zhejiang Chint Electronics Co. Ltd.	CHINT High-Tech Industrial Zone, North Baixiang, Yueqing 325603 Wenzhou Zhejiang	China

Rating and principal characteristics: 200/5A to 4000/5A, 10 VA to 30 VA, 50/60 Hz, acc class 0.5, FS5, Um: 0.72 kV, see annex

Trade mark (if any): CHINT

Model/Type reference: MES(BH-0.66) series

Additional information: -

Sample of product tested to be in conformity with IEC: 60044-1(ed.1);am1;am2

Test Report Ref. No: 2122165.50

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V.  
Utrechtseweg 310  
P.O. Box 5185  
6802 ED Arnhem  
The Netherlands

**KEMA Quality**  
a DEKRA company

Signed by: F.S. Strikwerda

Date of issue: 2010-04-13

ANNEX

CB TEST CERTIFICATE

Ref. Certificate No. NL-18075

page 1 of 1

## SPECIFICATION OF THE CERTIFIED PRODUCTS

### Product data

product	:	current transformer
trade name	:	CHINT
types	:	MES-30 (BH-0.66) 200/5A, 10 VA MES-30 (BH-0.66) 250/5A, 10 VA MES-30 (BH-0.66) 300/5A, 10 VA MES-30 (BH-0.66) 400/5A, 10 VA MES-40 (BH-0.66) 500/5A, 10 VA MES-40 (BH-0.66) 600/5A, 10 VA MES-60 (BH-0.66) 750/5A, 10 VA MES-60 (BH-0.66) 800/5A 10 VA MES-60 (BH-0.66) 1000/5A, 10 VA MES-100I (BH-0.66) 500/5A, 10 VA MES-100I (BH-0.66) 600/5A, 10 VA MES-100I (BH-0.66) 750/5A, 10 VA MES-100I (BH-0.66) 800/5A, 10 VA MES-100I (BH-0.66) 1000/5A, 10 VA MES-100I (BH-0.66) 1200/5A, 10 VA MES-100I (BH-0.66) 1500/5A, 10 VA MES-100II (BH-0.66) 2000/5A, 30 VA MES-100II (BH-0.66) 2500/5A, 30 VA MES-100II (BH-0.66) 3000/5A, 30 VA MES-100II (BH-0.66) 4000/5A, 30 VA
rated primary current	:	see types
rated secondary current	:	5 A
rated output	:	see types
accuracy class	:	0,5
highest voltage for equipment (Um)	:	0,72 kV
rated insulation level	:	3 kV
rated frequency	:	50/60 Hz
instrument security factor	:	FS 5
class of insulation	:	E