



CB TEST CERTIFICATE

Ref. Certificate No.

NL-31528

IEC SYSTEM OF CONFORMITY ASSESSMENT SCHEMES FOR ELECTROTECHNICAL EQUIPMENT AND COMPONENTS (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Circuit breakers for overcurrent protection		
Applicant:	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
Manufacturer:	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
Factory:	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
Rating and principal characteristics:	1P, 2P, 3P, 4P In = 1, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63 A B, C and D - type Ics = 7500 A Icn = Icn1 = 10000 A Ue: 240/415 Vac (1P); 415 Vac (2P, 3P, 4P); 50/60 Hz Uimp = 4 kV Grid distance "a" = 45 mm		
Trade mark (if any):	CHINT		
Model/Type reference:	NB1-63H		
Additional information:	Energy limiting class 3 according to EN 60898-1 for B and C type		
Sample of product tested to be in conformity with IEC:	60898-1(ed.1);am1;am2		
Test Report Ref. No:	3306216.50		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

Signed by: F.S.Strikwerda

Date of issue: 2014-07-21

