



Ref. Certif. No.  
**SE-86303**

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**

**CB TEST CERTIFICATE**

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory  
*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Residual current operated circuit-breaker with integral overcurrent protection for household and similar uses (RCBO's)

Zhejiang Chint Electrics Co., Ltd.  
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, 325603  
CHINA

Same as applicant

Same as applicant

$U_n = 220, 230, 240V\sim(2P)$   
 $I_n = 6, 10, 13, 16, 20, 25, 32, 40A$ , B- & C-type  
 $I_{\Delta n} = 0,03A$ , type-A  
 $I_{cn} = 10000A, I_{cs} = 7500A$ , Energy limiting class 3

**CHINT**

-

NB1L

-

IEC 61009-1:2010+A1+A2  
IEC 61009-2-1:1991

170101371SHA-002

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Box 1103  
SE-164 22 Kista, Sweden  
Int +46 8 750 00 00

Date: 15 March 2017



Signature:   
Bo Berglöf