



Ref. Certif. No.

SE-85180

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBO's)

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.  
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,  
Zhejiang Province, 325603, P.R. China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

Ue= 240V~(1P+N)  
In= 6, 10, 13, 16, 20, 25, 32, 40, 45, 50A; B- & C- Type  
IΔn=0,03A; Type-AC, Type-A  
Ics= 7500A, Icn= 10000A

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

NB3LEU

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 61009-1:2010+A1+A2  
IEC 61009-2-2:1991

As shown in the Test Report Ref. No. which forms part of this Certificate

160901954SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB  
Box 1103  
SE-164 22 Kista, Sweden  
Int +46 8 750 00 00

Date: 1 December 2016

Signature:

Bo Berglöv