

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

| | |
|---|---|
| Product | Residual current operated circuit-breakers without integral overcurrent protection (RCCB) |
| Name and address of the Applicant | Zhejiang Chint Electrics Co., Ltd No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang China |
| Name and address of the manufacturer | Zhejiang Chint Electrics Co., Ltd No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang China |
| Name and address of the factory | Zhejiang Chint Electrics Co., Ltd No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang China |
| Rating and principal characteristics | 1P + N Ue = 230 / 240 Vac, 50 Hz In = 25, 40, 63 A IΔn = 0,03, 0,1, 0,3 A Type B, without time-delay Inc = IΔc = 10000 A Im = IΔm = 500 A and 10 In whichever is greater Safety grid distance "a" = 50 mm Temperature limit: - 25 °C ... + 40 °C (-25°C was tested according to EN 62423) |
| Trademark (if any) | CHINT |
| Customer's Testing Facility (CTF) Stage used | |
| Model / Type Ref. | NL210 |
| Additional information (if necessary may also be reported on page 2) | |
| A sample of product was tested and found to be in conformity with IEC | IEC 62423:2009 |
| As shown in the test report Ref. No. which forms part of this certificate | 3310320.50 |

This CB Test Certificate is issued by the National Certification Body:

Meander 1051, NL-6825 MJ Arnhem, Netherlands
DEKRA Certification B.V.



Date: 2016-10-13

Signature: F.S.Strikwerda

