



CB TEST CERTIFICATE

Ref. Certificate No.

NL-30379

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Residual current circuit breakers with integral overcurrent protection (RCBO)		
Applicant:	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
Manufacturer:	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
Factory:	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
Rating and principal characteristics:	3P + N Ue = 400 Vac In = 6, 10, 13, 16, 20, 25, 32, 40 A B and C - type I Δ n = 0,03 A Type A and AC, without time-delay Ics = Icn = 6000 A I Δ m = Im = 3000 A Safety grid distance "a" = 50 mm Temperature limit: - 25 °C ... + 40 °C Reference ambient temperature : 30 °C		
Trade mark (if any):	CHINT		
Model/Type reference:	NB310L		
Additional information:	Energy limiting class 3 and -25°C temperature limit tested according to EN 61009-1		
Sample of product tested to be in conformity with IEC:	61009-1(ed.3);am1 61009-2-1(ed.1)		
Test Report Ref. No:	3305783.50		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

Signed by: F.S.Strikwerda

Date of issue: 2014-04-24

