



Ref. Certif. No.

**SE-85096**

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**

**CB TEST CERTIFICATE**

Product

Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBO's)

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.  
No.1,Chint Road,Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, 325603  
CHINA

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

Ue= 240V~(1P+N)  
In= 1, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40A, C-type  
IΔn= 10, 30mA, type-AC  
Icn= Ics= 6000A(NBH8LE-40H), 4500A(NBH8LE-40)

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

NBH8LE-40H, NBH8LE-40

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 61009-2-2:1991  
IEC 61009-1:2010+A1+A2

As shown in the Test Report Ref. No. which forms part of this Certificate

161000547SHA-001

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Box 1103  
SE-164 22 Kista, Sweden  
Int +46 8 750 00 00

Date: 23 November 2016



Signature:

Bo Berglöf