



Ref. Certif. No.

HU-002246

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnector

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone,
North Baixiang, Yueqing,
Zhejiang Province 325603, P.R. China

Name and address of the manufacturer

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone,
North Baixiang, Yueqing,
Zhejiang Province 325603, P.R. China

Name and address of the factory

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone,
North Baixiang, Yueqing,
Zhejiang Province 325603, P.R. China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

AC-22A/AC-22B; 1P+N, 3P+N; Ue:415V AC, 50/60Hz;
Ie:63A, 80A, 100A; Ith:100A; Ui:500V; Uimp:4,0kV;
Icm:20Ie; Icw:12Ie, 1s
(see Test item particulars of Test Report for further ratings)

Trademark (if any))



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NHB2-100UK

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2008 + AMD1:2012 + AMD2:2015
IEC 60947-1:2007 + AMD1:2010 + AMD2:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

1W180353

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.hu

Date: 2018-06-15

Signature:

Gabor Kassai

