



CB TEST CERTIFICATE

Ref. Certificate No.

NL-36422

IEC SYSTEM OF CONFORMITY ASSESSMENT SCHEMES FOR ELECTROTECHNICAL EQUIPMENT AND COMPONENTS (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Moulded-Case Circuit Breaker		
Applicant:	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
Manufacturer:	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
Factory:	Zhejiang Chint Electrics Co., Ltd	No.1318, Binhai No.2 Avenue, Economic and Technical Development Zone, Wenzhou City, Zhejiang Province,	China
Rating and principal characteristics:	Ue: 220 / 230 / 240 / 380 / 400 / 415 / 660 / 690 Vac for 3P and 4P 220 / 230 / 240 / 380 / 400 / 415 for 2P In: 16 A, 20 A, 25 A, 30 A, 32 A, 40 A, 50 A, 60 A, 63 A, 75 A, 80 A, 100 A, 125 A, 50 / 60 Hz Ui: 800 Vac, Uimp: 8 kV, 2P, 3P and 4P (unprotected N pole) Icu: 85 kA at 240 Vac, 65 kA at 415 Vac, 10 kA at 690 Vac (only 3P/4P) for R series 65 kA at 240 Vac, 50 kA at 415 Vac, 8 kA at 690 Vac (only 3P/4P) for H series Ics = 50% Icu See annex for further ratings		
Trade mark (if any):	CHINT		
Model/Type reference:	NM1-125R, NM1-125H		
Additional information:	This certificate is based on and replaces the certificate no. NL-18991 issued on 2010-09-20.		
Sample of product tested to be in conformity with IEC:	60947-2(ed.4);am1;am2		
Test Report Ref. No:	3307670.50		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

Signed by: F.S.Strikwerda

Date of issue: 2015-06-29



Ratings:

number of poles	: 2P, 3P and 4P (unprotected N pole)
protected pole	: 2 or 3
rated operational voltage (Ue)	: 220 / 230 / 240 / 380 / 400 / 415 / 660 / 690 Vac for 3P and 4P 220 / 230 / 240 / 380 / 400 / 415 Vac for 2P
rated insulation voltage (Ui)	: 800 Vac
rated impulse withstand voltage (Uimp)	: 8 kV
rated current (In)	: 16 A, 20 A, 25 A, 30 A, 32 A, 40 A, 50 A, 60 A, 63 A, 75 A, 80 A, 100 A, 125 A
rated operational current (Ie)	: Equal to In
conventional thermal current (Ith)	: Equal to In
current rating for four-pole circuit-breakers	: Equal to In
rated frequency	: 50 / 60 Hz
reference temperature	: 40 °C
rated ultimate short-circuit breaking capacity (Icu)	: 85 kA at 220 / 230 / 240 Vac, 65 kA at 380 / 400 / 415 Vac, 10 kA at 660 / 690 Vac (only 3P/4P) for R series 65 kA at 220 / 230 / 240 Vac, 50 kA at 380 / 400 / 415 Vac, 8 kA at 660 / 690 Vac (only 3P/4P) for H series
rated service short-circuit breaking capacity (Ics)	: Ics = 50% Icu
suitable for isolation	: Suitable
utilization category	: A
safety distance (screen-circuit breaker)	: Front / Back: 0 mm, Left / Right: 50 mm, Up / Down: 50 mm
instantaneous release	: Magnetic type, fixed, 2 poles in series: $I_i = 10 I_n$ single pole: $12 I_n$
time setting of the instantaneous release	: Fixed
inverse time delay release	: Thermal type, fixed
time setting of the inverse time delay release	: Fixed Trip time at $2 I_n$: $30 \text{ s} \leq t \leq 540 \text{ s}$
EMC environment	: A and B
Individual pole short-circuit breaking capacity (I _{su})	: N/A
Individual pole short-circuit breaking capacity (I _{IT})	: N/A
line/load terminal connection	: Marked Copper conductor with cable lug

Additional information:

Nomenclature breakdown:

NM1-125x/y300

a b c d

a = Model name: NM1

b = Frame size: 125

c = short-circuit capacity, 'R' or 'H'

d = pole numbers, '4' means 4P MCCBs, '3' means 3P MCCBs, '2' means 2P MCCBs