



CB TEST CERTIFICATE

Ref. Certificate No.

NL-26601

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Moulded-Case Circuit Breaker		
Applicant:	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
Manufacturer:	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
Factory:	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
Rating and principal characteristics:	Ue: 220 / 380 Vac Ui: 750 Vac Uimp: 8 kV In: 500 A, 600 A, 630 A 3P Icu: 65 kA at 220 Vac, 40 kA at 380 Vac Ics = 100% Icu See annex for further ratings		
Trade mark (if any):	CHINT		
Model/Type reference:	NM1G-630		
Additional information:			
Sample of product tested to be in conformity with IEC:	60947-2(ed.4);am1		
Test Report Ref. No:	3304744.50		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands



Signed by: F.S. Strikwerda

Date of issue: 2013-05-03

Ratings:

number of poles	: 3P
protected pole	: 3
rated operational voltage (Ue)	: 220 / 380 Vac
rated insulation voltage (Ui)	: 750 Vac
rated impulse withstand voltage (Uimp)	: 8 kV
rated current (In)	: 500 A, 600 A, 630 A
rated operational current (Ie)	: Equal to In
conventional thermal current (Ith)	: Equal to In
current rating for four-pole circuit-breakers	: N/A
rated frequency	: 50 / 60 Hz
rated ultimate short-circuit breaking capacity (Icu)	: 65 kA at 220 Vac, 40 kA at 380 Vac
rated service short-circuit breaking capacity (Ics)	: Ics = 100% Icu
Individual pole short-circuit breaking capacity (I _{IT})	: N/A
suitable for isolation	: Suitable
utilization category	: A
safety distance (screen-circuit breaker)	: Front / Back: 0 mm, Left / Right: 100 mm, Up / Down: 100 mm
instantaneous release	: Magnetic type, fixed, 2 poles in series: $I_i = 10 I_n$ single pole: $12 I_n$
time setting of the instantaneous release	: Fixed
inverse time delay release	: Thermal type, fixed
time setting of the inverse time delay release	: Fixed
method of mounting	: Fixed
EMC environment	: A and B
circuit-breaker for use on phase-earthed systems	: N / A
circuit-breaker for use in IT systems	: N / A
line/load terminal	: Marked
connection	: Copper conductor with cable lug