

ATTESTATION OF CONFORMITY

Number: 2122165.01A

Issued to: Zhejiang Chint Electrics Co. Ltd.
CHINT High-Tech Industrial Zone
North Baixiang, Yueqing
325603 Wenzhou Zhejiang
China

For the product: current transformers

Trade name: CHINT

Type/Model: MES(BH-0.66) series

Ratings: primary current: 200-4000 A, secondary current: 5 A, 50/60 Hz,
class 0.5, FS 5, Um 0.72 kV, Insulation level 3 kV

Manufactured by: Zhejiang Chint Electrics Co. Ltd.
CHINT High-Tech Industrial Zone
North Baixiang, Yueqing
325603 Wenzhou Zhejiang
China

Requirements: EN 60044-1:1999, A2:2003, A1:2000, IEC 60044-1:1996, A2:2002, A1:2000
Clauses: 7.2, 8.1, 8.3, 8.4, 11.4, 11.5 and 11.6

This Attestation is granted on account of an examination by KEMA, the results of which are laid down in a confidential test report no 2122165.01-QUA/COM.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by KEMA is not the responsibility of KEMA.

Arnhem, December 18, 2009



KEMA Quality B.V.

F.S. Strikwerda
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed