

# C E R T I F I C A T E



of Conformity  
Low Voltage Directive 2006/95/EC

Registration No.: AN 50301440 0001

Report No.: 15079067 001

Holder: Zhejiang Chint Electrics Co., Ltd.  
No.1,  
Chint Road, Chint Industrial Zone,  
North Baixiang  
Yueqing, Zhejiang Province 325603  
P.R. China

Product: Magnetic Contactor  
(AC Contactor)


Identification: Type Designation : NCK3-90  
Standard : EN60947-4-1:2010+A1  
Ratings : AC-8a, Ue=230(220)/400(380)VAC, Ie=90A  
Ue=600VAC, Ie=60A, Ith=100A, Ui=690V, Uimp=6,0kA, 3P,  
Us= AC24V/36V/110V/120V/220V/240V/277V/480V, 50/60Hz  
Serial No. : Engineering samples  
Remark: Refer to test report 15079067 001 for details

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with all revision of Annex I of Council Directive 2006/95/EC, in its latest amended version, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex III of the Directive.



Certification Body

Shanghai, 13.03.2015

  
Jie Zhang

TÜV Rheinland Shanghai Ltd. - Shanghai 200072 - P.R.China

CE The CE marking may be used if all relevant and effective EC Directives are complied with. CE

# C E R T I F I C A T E



of Conformity  
Low Voltage Directive 2006/95/EC

Registration No.: AN 50301440 0002

Report No.: 15079067 001

Holder: Zhejiang Chint Electrics Co., Ltd.  
No.1,  
Chint Road, Chint Industrial Zone,  
North Baixiang  
Yueqing, Zhejiang Province 325603  
P.R. China

Product: Magnetic Contactor  
(AC Contactor)

Identification: Type Designation : NCK3-75  
Standard : EN60947-4-1:2010+A1  
Ratings : AC-8a; Ue=230(220)/400(380)VAC; Ie=75A  
Ue=600VAC, Ie=50A; Ith=100A; Ui=690V; Uimp=6,0kA; 3P,  
Us= AC24V/36V/110V/120V/220V/240V/277V/480V, 50/60Hz  
Serial No. : Engineering samples  
Remark: Refer to test report 15079067 001 for details.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with all revision of Annex I of Council Directive 2006/95/EC, in its latest amended version, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex III of the Directive.

Shanghai, 13.03.2015



Certification Body

  
Jie Zhang

TÜV Rheinland Shanghai Ltd. - Shanghai 200072 - P.R.China

CE The CE marking may be used if all relevant and effective EC Directives are complied with. CE