



BV LCIE
CHINA
Number N°1766AS07CNTC25188

ATTESTATION of conformity with European Directives

Product: Fuse-switch disconnecter
Reference NHRT41-630/3, NHRT41-630/3L, NHRT41-400/3, NHRT41-400/3L
 NHRT41-250/3, NHRT41-250/3L
Issued to Zhejiang Chint Electrics co.,ltd
Address No.1 CHINT Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang, China
Manufacturer Zhejiang Chint Electrics co.,ltd
Technical characteristics Ui: 800V; Ith: 250A, 400A, 630A
 Ue: 500V; Ie: 250A, 400A, 630A
 Iq: 50kA; AC-22B

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60947-3:2009+A1:2012+A2:2015 EN 60947-1:2007+A1:2011+A2:2014	CNTC-17MY0476ITSP	14/07/2017

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
 The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China),), July 17th, 2017.



Charlie CHEN
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
 Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有限公司
Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com