



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE160304005100

Product

Soft Starter

Applicant

Zhejiang CHINT Electrics Co.,Ltd.

No.1 CHINT Road, CHINT Industrial Zone, North Baixiang,
Yueqing, Zhejiang Province, P.R.China

Type/model

NJR3-110/380,NJR3-150/380,NJR3-110/440, NJR3-
150/440,NJR3-110/500,NJR3-150/500, NJR3-110/660,NJR3-
150/660

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-
CE2016CQC0304-007969, the submitted sample of the above item complies with:

EN 60947-4-2: 2012

and fulfill testing requirement of the European Directive:

2014/35/EU

President:



Date of issue: Aug.29,2016

Date of expiration: Aug.29,2019



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE160304005100

NJR3-110/380,NJR3-150/380,NJR3-110/440,
NJR3-150/440,NJR3-110/500,NJR3-150/500,
NJR3-110/660,NJR3-150/660
NJR3-110/380,NJR3-150/380,NJR3-110/440,NJR3-150/440,
NJR3-110/500,NJR3-150/500,NJR3-110/660,NJR3-150/660
NJR3-110/380,NJR3-150/380 Ui: 660V;
NJR3-110/440,NJR3-150/440 Ui: 660V;
NJR3-110/500,NJR3-150/500 Ui: 1000V ;
NJR3-110/660, NJR3-150/660 Ui: 1000V ;
NJR3-110/380,NJR3-110/440,NJR3-110/500,NJR3-110/660
Ith: 110A;
NJR3-150/380,NJR3-150/440,NJR3-150/500,NJR3-150/660 Ith: 150A;
NJR3-110/380,NJR3-150/380 Ue: AC380V;
NJR3-110/440,NJR3-150/440 Ue: AC440V;
NJR3-110/500,NJR3-150/500 Ue: AC500V;
NJR3-110/660,NJR3-150/660 Ue: AC660V;
NJR3-110/380,NJR3-110/440,NJR3-110/500,NJR3-110/660 Ie: 103A;
NJR3-150/380,NJR3-150/440,NJR3-150/500,NJR3-150/660 Ie: 140A;
AC-53a;
3P