



# 产品认证证书

证书编号: CQC18002210544

申请人名称及地址

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

制造商名称及地址

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产企业名称及地址

浙江正泰电器股份有限公司(V014025)  
浙江省乐清市北白象镇正泰智能电器工业园区长江路2号

产品名称和系列、规格、型号

继电器

NJX2 系列 触点负载: 10A 250VAC/30VDC; 线圈电压: 6VAC, 12VAC, 24VAC, 36VAC, 48VAC, 110VAC, 127VAC, 220VAC, 230VAC, 240VAC, 380VAC, 400VAC, 415VAC 3VA; 5VDC, 6VDC, 9VDC, 12VDC, 18VDC, 24VDC, 28VDC, 36VDC, 48VDC, 60VDC, 90VDC, 110VDC, 127VDC, 220VDC 2W; 电气寿命: 100000 周期; 机械寿命: 2000000 周期; 环境温度: -40℃~70℃; RTI

产品标准和技术要求

GB/T21711.1-2008

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC11-462155-2010 认证规则的要求, 特发此证。

发证日期: 2019 年 01 月 17 日

本证书的有效性依据发证机构的定期监督获得保持。

主任: 陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0139431



# PRODUCT CERTIFICATE

**CERTIFICATE NO.: CQC18002210544**

**NAME AND ADDRESS OF THE APPLICANT**

Zhejiang CHINT Electrics Co., Ltd.  
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE MANUFACTURER**

Zhejiang CHINT Electrics Co., Ltd.  
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE FACTORY**

Zhejiang CHINT Electrics Co., Ltd. (V014025)  
No.2, Changjiang Road, CHINT Intelligent Electric Appliance Industrial Zone, North Baixiang, Yueqing ,  
Zhejiang Province, P.R.China

**PRODUCT NAME, MODEL AND SPECIFICATION**

Relay

NJX2 Series Contact loads: 10A 250VAC/30VDC; Coil voltage: 6VAC, 12VAC, 24VAC, 36VAC, 48VAC, 110VAC, 127VAC, 220VAC, 230VAC, 240VAC, 380VAC, 400VAC, 415VAC 3VA; 5VDC, 6VDC, 9VDC, 12VDC, 18VDC, 24VDC, 28VDC, 36VDC, 48VDC, 60VDC, 90VDC, 110VDC, 127VDC, 220VDC 2W; Electrical endurance: 100000 cycle; Mechanical endurance: 2000000 cycle; Ambient temperature: -40°C ~ +70°C; RTI

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T21711.1-2008

**TYPE OF CERTIFICATION SCHEMES**

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462155-2010 .

Valid from: Jan.17,2019

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

President: \_\_\_\_\_

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0139431




# 产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC18002210544

纸 号: 139431



线圈电压(Coil Voltage)	AC: (6~415)V, DC: (5~220)V
附加功能 (Additional features)	(D): (带通电指示功能 With power indicator) (可选 Optional) (J): (带机械指示功能 With mechanical indication) (可选 Optional) (BS): (带机械闭锁功能 With mechanical locking) (可选 Optional)

注: 此附录与证书同时使用时有效。

主任: 陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>