



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2010010307423968

NAME AND ADDRESS OF THE APPLICANT

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

NOARK Electrics (Shanghai) Co., Ltd. (V012845)
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Air Circuit Breaker

NA8-2500;Uimp:12kV;Ui:1000V;Ue: AC415V, AC690V;In: 1000A、1250A、1600A、2000A、2500A;Over-current ReleaseType: ETU;Ics= 80kA (AC415V) ;50kA (AC690V) ;Icu= 90kA (AC415V) ;50kA (AC690V) ;Icw=1s; 65kA (AC415V) ;50kA (AC690V) ;Utilization Category: B; Poles: 3P, 4P; Suitable for isolation;Attached Auxiliary Contacts:3NO3NC, 5NO5NC; Ith=6A;Ue/Ie: AC-15 AC230V/1.3A,AC400V/0.75A;Ue/Ie: DC-13 DC110V/0.55A,AC220V/0.27A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: Jun.01,2020

Valid until: Dec.16,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President:

Lu Mei

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>