



产品认证证书

证书编号: CQC2019010307167295

申请人名称及地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

制造商名称及地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产企业名称及地址

上海诺雅克电气有限公司(V012845)
上海市松江区思贤路3857号

产品名称和系列、规格、型号

万能式断路器

NA8-4000H; 详情见附件

产品标准和技术要求

GB/T14048.2-2008

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求, 特发此证。

发证日期: 2020年06月01日 有效期至: 2021年03月11日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: _____

陆楠



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0290289



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2019010307167295

NAME AND ADDRESS OF THE APPLICANT

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province

NAME AND ADDRESS OF THE FACTORY

NOARK Electrics (Shanghai) Co., Ltd. (V012845)
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Air-Circuit Breaker
NA8-4000H; See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: Jun.01,2020

Valid until: Mar.11,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0290289



产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC2019010307167295

纸 号: 290289

NA8-4000H;

额定冲击耐受电压 (U_{imp}): 12kV;

额定绝缘电压 (U_i): 1140V;

额定工作电压 (U_e): AC1000V/AC1140V;

额定电流 (I_n): 2000A, 2500A, 2900A, 3200A, 3600A, 4000A;

过电流脱扣器类型: 电子式;

额定运行短路分断能力 (I_{cs}): 50kA;

额定极限短路分断能力 (I_{cu}): 50kA;

额定短时耐受电流 (I_{cw}): 50kA/1s;

使用类别: B;

极数: 3P, 4P;

适用隔离;

适用频率: 50/60Hz;

配用的辅助触头 4N04NC, 6N06NC:

I_{th} : 5A;

AC-15: U_e/I_e : AC240V/ AC415V /2A;

DC-13: U_e/I_e : DC110V/ DC220V/ 0.3A;

符合附录 N 的电子附件:

分励脱扣器: SHT; U_s : AC240V, AC400/415V, DC220V, DC110V;

欠压脱扣器: UVT; U_s : AC240V, AC400/415V;

闭合电磁铁: XF; U_s : AC240V, AC400/415V, DC220V, DC110V

注: 此附录与证书同时使用时有效。

主任: _____

陆杨



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>