



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2006010307206459

NAME AND ADDRESS OF THE APPLICANT

Zhejiang CHINT Electric Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang CHINT Electric Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

NOARK Electric (Shanghai) Co., Ltd. (V012845)
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Conventional Circuit-Breaker
NA8-6300;Ue:AC400V;In:4000A,5000A,6300A;Ics=Icu:125kA;Icw=100kA/ 1s;Utilization
Category:B;Poles:3P;Auxiliary
Contacts:AC-15:Ue/Ie:AC230V/2A,AC400V/2A;DC-13:Ue/Ie:DC110V/0.3A,DC220V/0.3A;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection
This is to certify that the above mentioned product(s) complies with the requirements of certification
rules of CQC11-462141-2019 .

Valid from: Jun.01,2020

Valid until: Nov.07,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing
certification body until the expiry date.

President:

Lu Mei

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>