



# 产品认证证书

证书编号: CQC2015010307763761

**申请人名称及地址**

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

**制造商名称及地址**

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

**生产企业名称及地址**

上海诺雅克电气有限公司(V012845)  
上海市松江区思贤路3857号

**产品名称和系列、规格、型号**

塑料外壳式断路器  
NM8N-1600, NM8NDC-1600; 详情见附件

**产品标准和技术要求**

GB/T14048.2-2008

**认证模式**

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求, 特发此证。

发证日期: 2020年06月01日      有效期至: 2024年12月16日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任: \_\_\_\_\_

陆楠



## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0290261



# PRODUCT CERTIFICATE

**CERTIFICATE NO.:** CQC2015010307763761

**NAME AND ADDRESS OF THE APPLICANT**

Zhejiang CHINT Electronics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE MANUFACTURER**

Zhejiang CHINT Electronics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE FACTORY**

NOARK Electrics (Shanghai) Co., Ltd. (V012845)  
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

**PRODUCT NAME, MODEL AND SPECIFICATION**

Moulded Case Circuit-breaker  
NM8N-1600, NM8NDC-1600; See the appendix

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T14048.2-2008

**TYPE OF CERTIFICATION SCHEMES**

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

**Valid from:** Jun.01,2020

**Valid until:** Dec.16,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

**President:**

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

C 0290261





# 产品认证证书

附录

第 1 页 共 4 页

证书编号: CQC2015010307763761

纸号: 290261

NM8N-1600, NM8NDC-1600

$U_{imp}$ : 8kV;

$U_i$ : 1000V;

$U_e$ : AC380/400/415V, AC440V (仅热磁式), AC500V (仅热磁式), AC660/690V, DC1000V (仅 NM8NDC-1600 型 4P 适用), DC750V (仅 NM8NDC-1600 型 3P 适用);

$I_n$ : 630A, 800A, 1000A, 1250A, 1600A (电动机保护最大电流 1250A);

过电流脱扣器类型: 热磁式, 电子式;

热磁式:

$I_{cs}$ : AC380/400/415V: 50kA/70kA/70kA (S/Q/H); AC440V: 40kA/50kA (S/Q); AC500V: 30kA/40kA (S/Q); AC660/690V: 30kA;

DC1000V: 25kA/36kA (B/C); DC750V: 25kA/36kA (B/C);

$I_{cu}$ : AC380/400/415V: 50kA/70kA/100kA (S/Q/H); AC440V: 50kA/65kA (S/Q); AC500V: 40kA/50kA (S/Q); AC660/690V: 30kA;

DC1000V: 25kA/36kA (B/C); DC750V: 25kA/36kA (B/C);

电子式:

$I_{cs}$ : AC380/400/415V: 50kA/70kA/70kA (S/Q/H); AC660/690V: 30kA;

$I_{cu}$ : AC380/400/415V: 50kA/70kA/100kA (S/Q/H); AC660/690V: 30kA;

$I_{cw}$ : 20kA/1s (仅电子式);

使用类别: A (热磁式), B (电子式);

极数: 3P, 4P (三个保护极, N 极可开闭);

适用于隔离;

50/60Hz;

符合附录 N 的电子附件:

分励脱扣器: AC220/230V, AC380/400V;

注: 此附录与证书同时使用时有效。

主任: \_\_\_\_\_

陆杨

## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





# 产品认证证书


附录

第 2 页 共 4 页

证书编号: CQC2015010307763761

纸号: 290261

欠压脱扣器: AC220/230V, AC380/400V;  
配用的辅助报警触头: AX21-M8, AL21-M8  
3NO3NC;  
Ith: 5A ;  
AC-15: Ue/Ie: AC110V/5A; AC240V/4A, AC415V/2A;  
DC-13: Ue/Ie: DC110V/0.25A, DC220V/0.25A;  
NM8NDC-1600 接线图



注: 此附录与证书同时使用时有效。

主任:

陆梅



## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



# 产品认证证书

附录

第 3 页 共 4 页

证书编号: CQC2015010307763761

纸 号: 290261

型号解释:

注: 此附录与证书同时使用时有效。

主任: \_\_\_\_\_

陆杨



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





# 产品认证证书

附录

第 4 页 共 4 页

证书编号: CQC2015010307763761

纸 号: 290261

N M 8 N DC - 1600 □

① ② ③ ④ ⑤ ⑥ ⑦

① 企业特征代号

② 塑料外壳式断路器

③ 设计序号

④ 代表新, 与现产品有迭代关系

⑤ DC 表示直流, 无表示交流

⑥ 壳架等级电流 1600A

⑦ 分断能力特征代号: 交流: 标准型用 S 表示; 较高型用 Q 表示; 最高型用 H 表示;  
直流: 标准型用 B 表示; 较高型用 C 表示

注①: 附件有辅助触头、报警触头、欠压脱扣器、分励脱扣器、电动操作机构和旋转操作手柄等, 代号在型号上不体现, 可在产品的其他地方体现。附件代号: (辅助触头与报警触头结构完全一样, 只是从功能上作区分且 NM8N 全系列通用)

名称		规格	
辅助触头	AX21-M8,AL21-M8	3C 证书编号: 2013010304602112	
报警触头			
分励脱扣器	AC220/230V		
	AC380/400V		
欠压脱扣器	AC220/230V		
	AC380/400V		
闭合电磁铁 (NM8N-1600)	AC220/230V		
	AC380/400V		
电动操作机构 (NM8N-1600)	DC110/220V		
	AC110V、AC220/230V、AC380/400V		

② 4C 表示 N 级安装过电流脱扣器, 且与其他极一起合分, 动作电流: 0, 0.5, 1Ir

③ B/C/S/Q/H 型内部结构完全一致, 仅品牌标识不同;

注: 此附录与证书同时使用时有效。

主任:

陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>