

ATTESTATION OF CONFORMITY

Issued to: Zhejiang Chint Electrics Co., Ltd.
No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
325603 Zhejiang, China

For the product: Moulded-Case Circuit-Breaker

Trade name: CHINT

Type/Model: NXMS-1000H, NXMSP-1000H, NXMSH-1000H, NXMS-1000S, NXMSP-1000S and
NXMSH-1000S

Ratings: Ue: 220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac, 50 / 60 Hz
Ui: 1000 V, Uimp: 12 kV, 3P and 4P (N pole with or without overcurrent protection)
See annex for further ratings

Manufactured by: Zhejiang Chint Electrics Co., Ltd.
No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
325603 Zhejiang, China

Subject: Type test

Requirements: EN 60947-2:2017, EN 60947-2:2017 + A1:2020,
IEC 60947-2:2016, IEC 60947-2:2016 + A1:2019

Remark: This attestation replaces AOC no. 3312008.01A issued on 2018-06-19 and
no. 3312009.01A issued on 2018-05-31.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test reports no 3320069.50 and 3320069.51 issued on 2021-09-14.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Wenzhou, Zhejiang, 09 October 2021

Number: 3320069.01A

DEKRA Testing Services (Zhejiang) Co., Ltd.

Ms J Guo
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed
The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

DEKRA Testing Services (Zhejiang) Co., Ltd.
No. 5, Changjiang Road, Great Bridge Industrial Park, North Baixiang, 325603 Wenzhou, Zhejiang, China
T +86 57762 868000 F +86 57762 919889 www.dekra-certification.com



Ratings:

number of poles	: 3P and 4P (N pole with or without overcurrent protection)
protected pole	: 3 or 4
rated operational voltage (Ue)	: 220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac
rated insulation voltage (Ui)	: 1000 V
rated impulse withstand voltage (Uimp)	: 12 kV
rated frequency	: 50 / 60 Hz
rated current (In)	: 1000 A, 800 A
conventional thermal current (Ith)	: Equal to In
current rating for four-pole circuit-breakers	: 0,5 In, 1 In, OFF
rated short-time withstand current (Icw)	: 12 kA / 1 s at 220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac
Individual pole short-circuit breaking capacity (lit)	: 9,6 kA at 415 Vac
suitable for isolation	: Suitable
selectivity category	: B
safety distance (screen-circuit breaker)	: Front / Back: 0 mm, Left / Right: 100 mm, Up / Down: 100 mm
method of mounting	: Fixed
EMC environment	: A and B
rated tightening torque for terminals	: 30 Nm
line/load terminal	: Marked
connection	: Copper conductor with cable lug or copper bar
inverse time delay release	: Ir (inverse time delay tripping setting): 500 A, 550 A, 600 A, 630 A, 660 A, 700 A, 750 A, 800 A (In: 800 A) 630 A, 680 A, 720 A, 780 A, 820 A, 900 A, 950 A, 1000 A (In: 1000 A)
time setting of the inverse time delay release	: 12 s, 60 s, 100 s, 150 s with tolerance of $\pm 20\%$ (at 2 Ir) Trip time at 2 Ir: Set at 12 s: 12 s $\pm 20\%$ Set at 150 s: 150 s $\pm 20\%$
short time delay release	: Isd (short time delay tripping setting): (1,5, 2, 3, 4, 5, 6, 8) x Ir or OFF
time setting of short time delay release	: tsd (short time delay tripping setting): 0,3 s with tolerance of $\pm 0,06$ s Non-tripping duration: 0,24 s
instantaneous release	: Ii (instantaneous tripping setting): (2, 3, 4, 6, 8, 10, 12) x In or OFF
time setting of the instantaneous release	: Fixed

ratings - NXMS-1000H/NXMSP-1000H/NXMSH-1000H

rated service short-circuit breaking capacity (Ics)	: 75 kA at 220 Vac / 230 Vac / 240 Vac 50 kA at 380 Vac / 400 Vac / 415 Vac
rated ultimate short-circuit breaking capacity (Icu)	: 100 kA at 220 Vac / 230 Vac / 240 Vac, 70 kA at 380 Vac / 400 Vac / 415 Vac

ratings - NXMS-1000S/NXMSP-1000S/NXMSH-1000S

rated service short-circuit breaking capacity (Ics)	: 50 kA at 220 Vac / 230 Vac / 240 Vac 36 kA at 380 Vac / 400 Vac / 415 Vac
rated ultimate short-circuit breaking capacity (Icu)	: 75 kA at 220 Vac / 230 Vac / 240 Vac 50 kA at 380 Vac / 400 Vac / 415 Vac

Additional information

Nomenclature breakdown:

NXMS - 1000 H / 4 300

a b c d

a = Model name: 'NXMS', 'NXMSP', 'NXMSH'

b = Frame size: '1000'

c = Short-circuit capacity: 'H' or 'S'

d = Pole numbers, '4' means 4P MCCBs, '3' means 3P MCCBs