

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCB's)

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing
325603 Zhejiang, China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

See page 2

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

NL1-63

Additional information (if necessary may also be reported on page 2)

The product fulfils the requirements of AS/NZS 61008.1: 2015.

A sample of the product was tested and found to be in conformity with

IEC 61008-1:2010+A1+A2
IEC 61008-2-1:1990

As shown in the Test Report Ref. No. which forms part of this Certificate

210700245SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, SwedenSignature: 

Date: 08 October, 2021

Quan Li

Rating and principal characteristics

$U_n = 230V\sim$ or $240V\sim$ or $110V\sim(1P+N)$

$I_n = 16, 25, 32, 40, 63A$

$I_{\Delta n} = 0,01A$ (only for $I_n = 16, 25, 32A$), Type A and AC

$I_{\Delta n} = 0,03, 0,1, 0,3A$, Type A and AC,

$I_{\Delta n} = 0,5A$, Type AC

$I_{\Delta c} = I_{nc} = 4,5kA\&6kA\&10kA$, 50/60Hz

Date: 08 October, 2021

Signature: 