

IEC**IECEE**

®

TM

Ref. Certif. No.

CN54642

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

AC Motor Starter

Name and address of the applicant

Zhejiang CHINT Electric Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town,
Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electric Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town,
Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang CHINT Electric Co., Ltd.
No.2 Changjiang Road, CHINT Intelligent Electric Appliance
Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang
Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NS2-32H;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity withIEC 60947-4-1:2018; IEC 60947-2:2016(5th Edition); IEC
60947-2:2016/AMD1:2019As shown in the Test Report Ref. No. which
forms part of this Certificate

00901- CB2021CQC-099069-1, 00901- CB2021CQC-099069-2

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Sep.03,2021

Signature:

谢肇煦

Xie ZhaoXu

CB 0064266

NS2-32H;
Uimp:8kV;
Ui:690V;
Ue:AC400/415V,AC690V;
In:0.1-0.16A,0.16-0.25A,0.25-0.4A,0.4-0.63A,0.63-1A,1-1.6A,1.6-2.5A,2.5-4A,4-6.3A,6-10A,
9-14A,13-18A,17-23A,20-25A,24-32A;
Ue=AC400V/415V,
Ics=100kA(0.1A-10A),25kA(9A-32A);
Icu=100kA(0.1A-10A),50kA(9A-32A);
Ue=AC690V,
Ics=100kA(0.1-1.6A),4kA(1.6-32A);
Icu=100kA(0.1-1.6A),4kA(1.6-32A);
Over current release type: Thermal
magnetic;
Selectivity category:A,AC-3;
Trip Class:10A;
Poles:3P;
Suitability for isolation

Page 1 of 1

Additional information (if necessary)

Date:

Sep.03,2021

Signature:

谢肇煦

Xie ZhaoXu